



# 中国国家强制性产品认证证书

证书编号: 2013010305658189

委托人名称、地址

克瑞流体系统(苏州)有限公司  
苏州工业园区润胜路1号

生产者(制造商)名称、地址

克瑞流体系统(苏州)有限公司  
苏州工业园区润胜路1号

生产企业名称、地址

克瑞流体系统(苏州)有限公司  
苏州工业园区胜浦分区润胜路1号

产品名称和系列、规格、型号

液位开关

UNS1000 Ui:230V;AC-12:Ue:AC230V, Ie:65mA;Ith:65mA; IP65;型号详见附录

产品标准和技术要求

GB 14048.5-2008

上述产品符合强制性产品认证实施规则  
CNCA-01C-011:2007的要求,特发此证。

发证日期: 2013年11月29日

有效期至: 2018年11月29日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0842598





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2013010305658189

## NAME AND ADDRESS OF THE APPLICANT

Crane Fluid & Gas system (Suzhou) Co., Ltd  
No.1 RunSheng Road, ShengPu SIP, Suzhou, JiangSu Province China

## NAME AND ADDRESS OF THE MANUFACTURER

Crane Fluid & Gas system (Suzhou) Co., Ltd  
No.1 RunSheng Road, ShengPu SIP, Suzhou, JiangSu Province China

## NAME AND ADDRESS OF THE FACTORY

Crane Fluid & Gas system (Suzhou) Co., Ltd  
No.1 RunSheng Road, ShengPu SIP, Suzhou, JiangSu Province China

## NAME, MODEL AND SPECIFICATION

Level Switch

UNS1000 Ui:230V;AC-12;Ue:AC230V,Ie:65mA;Ith:65mA; IP65;See the Appendix

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.5-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Nov.29,2013

Date of expiry: Nov.29,2018

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 0842598





# 中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2013010305658189

纸号: 0842598

型号的解释:

UNS1000 -  $\square$  /  $\square$  -  $\square$  -  $\square$  -  $\square$  /  $\square$   $\square$   
① ② ③ ④ ⑤ ⑥ ⑦ ⑧

① UNS1000: UNS1000 型液位开关

② 导杆和安装部位的材料, 定义如下:  
MS - 黄铜 W. Nr. MS58

③ 安装部位尺寸, 定义如下:  
T1/2 - G1/2 槽罐螺纹  
M20 × 1.5 - M20 × 1.5 安装螺纹

④ 电气连接, 定义如下:  
ST1 - 电缆接头 DIN43651, 3 针+接地

⑤ 浮子形式	介质最小密度	材料	型式	直径	最高温度	压力(+20°C)
BN18	0.64 g/cm <sup>3</sup>	丁晴橡胶	圆柱形	18mm	100°C	4 bar

⑥ 开关点数量  
L1 - 1 个开关点

⑦ 触点方式	触点额定值
1 - SPST (NO 常开)	230 V AC, 65mA, 15 VA/W

⑧ 总长度  $L_0 = \dots$  mm (最大 1000mm)

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





# Certificate of Registration

QUALITY MANAGEMENT SYSTEM - ISO 9001:2008

This is to certify that: Crane Fluid & Gas System (Suzhou)  
Co., Ltd.  
No. 1, Runsheng Road  
SIP  
Suzhou  
Jiangsu  
215126  
China

克瑞流体系统（苏州）有限公司  
中国  
江苏省  
苏州市  
工业园区  
润胜路1号  
邮编：215126

Holds Certificate No: **FM 533766**

and operates a Quality Management System which complies with the requirements of ISO 9001:2008 for the following scope:

The manufacture of valves and valve components. The manufacture of plastic lining piping systems. The assembly of control Products (Pressure Switch, Transducer, Level Switch, Air Suspension Valve) .

阀门及阀门零件的制造。塑料内衬管道系统的制造。控制部件（压力开关，压力变送器，液位开关，空气悬架阀）的装配。

For and on behalf of BSI:



**Gary Fenton, Global Assurance Director**

Originally registered: 16/06/2008

Latest Issue: 16/12/2013

Expiry Date: 15/12/2016



Page: 1 of 1

...making excellence a habit.™

This certificate was issued electronically and remains the property of BSI and is bound by the conditions of contract.

An electronic certificate can be authenticated [online](http://www.bsi-global.com/ClientDirectory).

Printed copies can be validated at [www.bsi-global.com/ClientDirectory](http://www.bsi-global.com/ClientDirectory) or telephone +86 10 8507 3000.

Further clarifications regarding the scope of this certificate and the applicability of ISO 9001:2008 requirements may be obtained by consulting the organization.

This certificate is valid only if provided original copies are in complete set.