



CERTIFICATE NUMBER
15-HG1374840-PDA

DATE
08 Jul 2015

ABS TECHNICAL OFFICE
Hamburg Engineering Department

CERTIFICATE OF DESIGN ASSESSMENT

This is to certify that a representative of this Bureau did, at the request of

BARKSDALE GMBH

assess design plans and data for the below listed product. This assessment is a representation by the Bureau as to the degree of compliance the design exhibits with applicable sections of the Rules. This assessment does not waive unit certification or classification procedures required by ABS Rules for products to be installed in ABS classed vessels or facilities. This certificate, by itself, does not reflect that the product is Type Approved. The scope and limitations of this assessment are detailed on the pages attached to this certificate.

Product: **Pressure Switch**

Model: **S9000**

This Product Design Assessment (PDA) Certificate 15-HG1374840-PDA, dated 08/Jul/2015 remains valid until 07/Jul/2020 or until the Rules or specifications used in the assessment are revised (whichever occurs first).

This PDA is intended for a product to be installed on an ABS classed vessel, MODU or facility which is in existence or under contract for construction on the date of the ABS Rules or specifications used to evaluate the Product.

Use of the Product on an ABS classed vessel, MODU or facility which is contracted after the validity date of the ABS Rules and specifications used to evaluate the Product, will require re-evaluation of the PDA.

Use of the Product for non ABS classed vessels, MODUs or facilities is to be to an agreement between the manufacturer and intended client.

AMERICAN BUREAU OF SHIPPING

Ulf (Ulf Numirski) Numirski
Engineer

NOTE: This certificate evidences compliance with one or more of the Rules, Guides, standards or other criteria of ABS or a statutory, industrial or manufacturer's standards. It is issued solely for the use of ABS, its committees, its clients or other authorized entities. Any significant changes to the aforementioned product without approval from ABS will result in this certificate becoming null and void. This certificate is governed by the terms and conditions as contained in ABS Rules 1-1-A3/5.9 Terms and Conditions of the Request for Product Type Approval and Agreement (2010).

BARKSDALE GMBH
DORN-ASSENHEIMER-STR.27
D-61203 REICHELSCHEIM
Germany
Telephone:
Fax:
Email: info@barksdale.de
Web: www.barksdale.de

Tier: 2 - PDA Issued

Product: Pressure Switch

Model: S9000

Intended Service:

Pressure control, alarm and monitoring functions for marine applications.

Description:

Diaphragm/ piston type sensor.

Rating:

Measuring ranges: 0.2 to 30 bar for diaphragm and 10 to 400 bar for piston type sensor.

Output: switch contact.

Repeatability: +/-10%, +/-4% for diaphragm and +/-2.0% for piston type sensor.

Ambient temperature: -10°C to 70°C for diaphragm and -20°C to 80°C for piston type sensor.

Maximum Contact Load: 10 A at 250 V AC, 6 A at 24 V DC

Degree of Protection: IP 65

Service Restriction:

Unit Certification is not required for this product. If the manufacturer or purchaser request an ABS Certificate for compliance with a specification or standard, the specification or standard, including inspection standards and tolerances, must be clearly defined.

The Manufacturer has provided a declaration about the control of, or the lack of Asbestos in this product.

Comments:

NA

Notes/Drawing/Documentation:

Drawing No. 923-1961 A, Dimension Drawing/ Data Sheet, Revision: A

Drawing No. DB Serie 9000 923-1646 DE, Data Sheet, Revision: E

Drawing No. S9000-BFSV-973-14, Test Report, Revision: -

Drawing No. UDS1_S9000_SV_BFSV-6761-09, Test Report, Revision: -

Terms of Validity:

This Product Design Assessment (PDA) Certificate 15-HG1374840-PDA, dated 08/Jul/2015 remains valid until 07/Jul/2020 or until the Rules or specifications used in the assessment are revised (whichever occurs first).

This PDA is intended for a product to be installed on an ABS classed vessel, MODU or facility which is in existence or under contract for construction on the date of the ABS Rules or specifications used to evaluate the Product.

Use of the Product on an ABS classed vessel, MODU or facility which is contracted after the validity date of the ABS Rules and specifications used to evaluate the Product, will require re-evaluation of the PDA.

Use of the Product for non ABS classed vessels, MODUs or facilities is to be to an agreement between the manufacturer and intended client.

STANDARDS

ABS Rules:

The Rules applicable to this assessment are:

BARKSDALE GMBH

DORN-ASSENHEIMER-STR.27

D-61203 REICHELSCHEIM

Germany

Telephone:

Fax:

Email: info@barksdale.de

Web: www.barksdale.de

Tier: 2 - PDA Issued

2015 Rules for Building and Classing Steel Vessels 1-1-4/7.7, 1-1-Appendix 3, 4-8-3/1.7/1.11.1/1.17, 4-9-8/13.1

National:

NA

International:

NA

Government:

NA

EUMED:

NA

OTHERS:

NA