



EXPLOSION PROTECTION

CERTIFICATE OF CONFORMITY

Cert NO.GYJ12.1026X

This is to certify that the product

Temperature Switches

manufactured by Barksdale Inc.

(Address:3211 Fruitland Avenue,Los Angeles,CA 90058-8043,USA)

which model is TX series

Ex marking Ex d II B+H2 T4/T6 Gb

product standard —

drawing number C981018 Rev.V、 C981022 Rev.Y

has been inspected and certified by NEPSI, and that it conforms to GB 3836.1-2010,GB 3836.2-2010

This Approval shall remain in force until 2017.03.01

Remarks 1.Conditions for safe use are specified in the attachment to this certificate.
2.Symbol "X" placed after the certification number denotes specific conditions of use, which are specified in the attachment to this certificate.
3.Model designation is specified in the attachment to this certificate.

Director



National Supervision and Inspection Centre for
Explosion Protection and Safety of Instrumentation

Issued Date 2012.03.02

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.